

RICOGNIZIONE ED AGGIORNAMENTO PARERI ENTI GESTORI –
ALLINEAMENTO DELLA PUBBLICA ILLUMINAZIONE ALLA
RISPONDENZA DELLA PREVISIONE PROGETTUALE SCELTA
DALL'AMMINISTRAZIONE IN ANNI RECENTI.

Per quanto riguarda i pareri degli enti gestori, come già ampiamente argomentato, sono stati espressi su schemi di opere di urbanizzazione che non variano rispetto agli attuali se non per il numero di utenze previste.

Per quanto riguarda l'illuminazione, si specifica che rispetto a quanto approvato variano i corpi illuminanti detti di tipo "B", che sono quelli sui camminamenti pubblici ed all'interno del verde pubblico.

Per il resto, i corpi illuminanti di tipo "B" saranno composti da pali di altezza pari a ml 4, come da concessione, pozzetto in c.l.s. per raccordo e alloggio dispersore a terra, compreso cavi di illuminazione.

I corpi illuminanti di tipo "A" saranno composti da pali di altezza pari a ml 8, come da concessione, pozzetto in c.l.s. per raccordo e alloggio dispersore a terra, compreso cavi di illuminazione.

Il tecnico



The image shows a handwritten signature in black ink, which appears to be 'L. Zoraini'. Overlaid on the signature is a circular official stamp. The stamp contains the text 'UFFICIO INGE. A.P.P.C. DI FIRENZE' around the top edge, 'ZORAINI' in the center, 'VERBA' below it, 'ARCHITETTO' below that, and 'SEZIONE A - SETTORE F' around the bottom edge. There are also small stars on either side of the bottom text.